

TAAEB320 AZ 12/12 3F 6P 1V




Zingonia 10000 m³/h test chamber
 Fan test laboratory AMCA 210/99 Fig. 12

Air Density (γ): 1.20 kg/m³
 Installation type "B" : free inlet, ducted outlet
 dB(A) free field noise measurements at 1 m

Type:	DD 12/12	Watt:	1100	Amp Max:	3.8
Motor:	14192C	Volt:	400 3~	Prot.:	IP 20
Test nr.:	S4387.*	Hz:	50	T.H.:	YES-OUT
Date:	10/04/2013	Poles:	6	Ins. Cl.:	F

ErP 2015



This test data obtained in a laboratory registered by AMCA for AMCA 210/99 air performance testing. Data is not certified by AMCA.


TAAEB6HX AZ 12/12 1F 6P 3V

NICOTRA **Gebhardt**

Zingonia 10000 m³/h test chamber
 Fan test laboratory AMCA 210/99 Fig. 12

Air Density (γ): 1.20 kg/m³
 Installation type "B": free inlet, ducted outlet
 dB(A) free field noise measurements at 1 m

Type:	DD 12/12	Watt:	735	Amp Max:	7.01
Motor:	14192F	Volt:	230 1~	Prot.:	IP 20
Test nr.:	S4647.*	Hz:	50	T.H.:	YES-OUT
Date:	19/06/2014	Poles:	6	Ins. Cl.:	F
		μ F	20/ 450 V		



This test data obtained in a laboratory registered by AMCA for AMCA 210/99 air performance testing. Data is not certified by AMCA.