

TAAE72177 AZ 7/7 1F 6P 1V


NICOTRA | **Gebhardt**

Zingonia 10000 m³/h test chamber
 Fan test laboratory AMCA 210/99 Fig. 12

Air Density (γ): 1.20 kg/m³
 Installation type "B": free inlet, ducted outlet
 dB(A) free field noise measurements at 1 m

Type:	DDM 7/7	Watt:	50	Amp Max:	0.65
Motor:	E5G3306	Volt:	230 1~	Prot.:	IP 55
Test nr.:	3787.*	Hz:	50	T.H.:	YES-OUT
Date:	06/06/2012	Poles:	6	Ins. Cl.:	F
		μ F:	2.5 / 450 V		

ErP 2015



This test data obtained in a laboratory registered by AMCA for AMCA 210/99 air performance testing. Data is not certified by AMCA.

TAAE729M AZ 7/7 1F 4P 1V


NICOTRA | **Gebhardt**

Zingonia 10000 m³/h test chamber
 Fan test laboratory AMCA 210/99 Fig. 12

Air Density (γ): 1.20 kg/m³
 Installation type "B": free inlet, ducted outlet
 dB(A) free field noise measurements at 1 m

Type:	DDM 7/7	Watt:	147	Amp Max:	1.6
Motor:	E5G3301	Volt:	230 1~	Prot.:	IP 55
Test nr.:	3701.*	Hz:	50	T.H.:	YES-OUT
Date:	12/10/2011	Poles:	4	Ins. Cl.:	F
		μ F:	5 / 450 V		

ErP 2015



This test data obtained in a laboratory registered by AMCA for AMCA 210/99 air performance testing. Data is not certified by AMCA.

TAAE72L7G AZ 7/7 1F 4P 1V


NICOTRA | **Gebhardt**

Zingonia 10000 m³/h test chamber
 Fan test laboratory AMCA 210/99 Fig. 12

Air Density (γ): 1.20 kg/m³
 Installation type "B": free inlet, ducted outlet
 dB(A) free field noise measurements at 1 m

Type:	DDM 7/7	Watt:	200	Amp Max:	2
Motor:	E5G5402	Volt:	230 1~	Prot.:	IP 55
Test nr.:	3698.*	Hz:	50	T.H.:	YES-OUT
Date:	04/10/2011	Poles:	4	Ins. Cl.:	F
		μ F:	5 / 450 V		

ErP 2015



This test data obtained in a laboratory registered by AMCA for AMCA 210/99 air performance testing. Data is not certified by AMCA.

TAAE72M9G AZ 7/7 1F 4P 3V


NICOTRA | **Gebhardt**

Zingonia 10000 m³/h test chamber
 Fan test laboratory AMCA 210/99 Fig. 12

Air Density (γ): 1.20 kg/m³
 Installation type "B": free inlet, ducted outlet
 dB(A) free field noise measurements at 1 m

Type:	DDM 7/7	Watt:	147	Amp Max:	1.43
Motor:	E5G5401	Volt:	230 1~	Prot.:	IP 44
Test nr.:	3877.*	Hz:	50	T.H.:	YES-OUT
Date:	19/03/2014	Poles:	4	Ins. Cl.:	F
		μ F	5 / 450 V		

ErP 2015



This test data obtained in a laboratory registered by AMCA for AMCA 210/99 air performance testing. Data is not certified by AMCA.